

No. 376/2021


CHC – Anandapuram

SANITARY CERTIFICATE

I hereby certify that I have inspected the St. Joseph's Public School Anandapuram Building No. XVII/170, Muriyad Grama Panchayath and premises of the Educational Institution and certify that the accommodation for the pupils, taught therein and is properly ventilated, that it is neat and clean, that the latrines arrangements adequate and satisfactory, that adequate number of girls friendly toilet, that the supply of drinking water is wholesome through a net work of taps and pipes connected to over head tank and that all other necessary respects for the sanitation is satisfactory for 2021 – 22 academic year.

Anandapuram

05/04/2021


**HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
ANANDAPURAM**


St. Joseph's Public School
P.O. Anandapuram - 680 305




**Manager
St. Joseph's Public School
Anandapuram**



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
CHALAKUDY, KIZHAKKUMPATTUKARA-THRISSUR
 Telephone No - 04802338380, E-mail - kwa.qcsdl.tsr@gmail.com



TC-10479

Test Report

Test Report. No: KWA/QCSDL/CLDY-TSR/003081/2022

ULR NO.: TC1047922000001006F

Report Date: 14.06.2022

Customer Name & Address			1. Date of Receipt : 10/06/2022		
ST JOSEPH PUBLIC SCHOOL P.O ANANDAPURAM 680305			2. Sampling done by : The Customer		
			3. UID No. of Sample: KWA/QCSDL/CLDY-TSR/S-003081/2022		
			4. Source of Sample : OPEN WELL		
			5. Sample Quantity : 2 litre		
			6. Test Performing Dates		
			From : 10/06/2022		To: 13/06/2022
1	Colour	HU	IS 3025 (part 4) -1983 (R. 2021)	5	5.00
2	Odour		IS 3025 (part 5) -2018		Agreeable
3	Turbidity	(NTU)	IS 3025 (part 10) - 1984 (R. 2017)	1	0.20
4	pH at 25°C		IS 3025 (part 11) - 2022	6.5 to 8.5	5.40
5	Total Alkalinity (as CaCO ₃)	(mg/litre)	IS 3025 (part 23) - 1986 (R. 2019)	200	26.00
6	Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (part 16) - 1984 (R. 2017)	500	76.78
7	Total Hardness (as Ca CO ₃)	(mg/litre)	IS 3025 (part 21) - 2009 (R. 2019)	200	30.00
8	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) - 1988 (R. 2019)	250	8.88
9	Calcium (as Ca)	(mg/litre)	IS 3025 (part 40) - 1991 (R. 2019)	75	6.41
10	Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46) - 1994 (R. 2019)	30	3.40

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Angelo Babu E

Quality Manager,
Quality Control Sub-District Laboratory
Kerala Water Authority
Chalaky. Thirissur - 680 005

KWA/QCSDL/CLDY-TSR No: 6
Rev.No: 00

Issue No: 1
Rev Date: 00

Issue Date 01/10/2021

Page 1 of 1

St. Joseph's Public School
P.O. Anandapuram - 680305

Dr. K. K. Maniam
Manager
St. Joseph's Public School
Anandapuram